

### DECLARATION OF CONFORMITY

We, Santon Holland bv, declare under our sole responsibility that the product:

Santon “**DFS-1/DFS-14** (described below), provided that it is installed, maintained and used in the application for which it is made, with respect of the “professional practices”, relevant installation standards and manufacturer’s instructions.  
 Domestic Firefighter safety Switch (DFS-1/DFS-1-W/DFS-1-MC/DFS-14/DFS-14-W/DFS-14-MC)

	All DFS-1*				All DFS14*			
	1000	850	800	650	1000	850	800	650
String Voltages (Vdc)	16	20	25	32	16	20	25	32
String Current (A)	2 poles, 0-1-0-1 4				poles, 0-1-0-1			
Switch version	1				1 or 2			
Number of Strings	100Vac - 240Vac							
Operating Voltage	230Vac							
Nominal Voltage	30mA							
Nominal Current	100mA							
Start up (loading) Current average	max 300mA							
Switch on Action Current	24Vdc - 300mA max							
Feedback contact	-20°C - +50°C							
Operating Temperature range	+100°C							
Maximum operating temperature before automatic switch OFF	-40°C - +85°C							
Storage Temperature range	IP65							
Protection Degree	Class II							
Protection Level	Approx. 1kg							
Weight	EN 60947 part 1+3							
CE certification	EN60947-1, DIN VDE 0100-712							
DC Switch disconnect according to	10.000							
Number of operations	>1500							
Number of operations under load (DC21)								

\* For DFS-1/14 and DFS-1/14-W please use correct M4 fork shoe

To which this declaration relates is in conformity with the following standard(s):

IEC 60947 part 1 and 3

complies with the provisions of Council Directive:

73 / 23 / EEC of 19 February 1973 (OJEC L 77 of 26-03-73) modified by Directive 93 / 68 / EEC of 22 July 1993 (OJEC L220 of 30-08-93) so called Low Voltage Directive (LVD) and can be incorporated in equipment coming under application to other Directives.

For Production Certificate ISO 9001:2015 no. NL018241/2-1 first issued by BVQI on August 28, 2015, Last issued by BVQI on October 30, 2017 valid until November 09, 2020.

Additional information:

This product is intended to be installed, maintained and used by professional or entitled persons.

Year of affixing the “CE” marking: 2006

Manager Q-SHE



F. Christiaanse

November 2018